

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise

Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
1	01-Mar-2023 18:11:50	Eq_1	poornima@dreamsoftindia.com	Eq_1Alarm Alerts IAS	Eq_1 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
2	01-Mar-2023 18:11:50	Eq_1	rohan@dreamsoftindia.com	Eq_1Alarm Alerts IAS	Eq_1 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
3	01-Mar-2023 18:11:50	Autoclave CH 2	rohan@dreamsoftindia.com	Autoclave CH 2Alarm Alerts IAS	Autoclave CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
4	01-Mar-2023 18:11:50	Autoclave CH 2	rohan@dreamsoftindia.com	Autoclave CH 2Alarm Alerts IAS	Autoclave CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
5	01-Mar-2023 18:11:50	Autoclave CH 8	rohan@dreamsoftindia.com	Autoclave CH 8Alarm Alerts IAS	Autoclave CH 8 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
6	01-Mar-2023 18:11:50	Autoclave CH 8	rohan@dreamsoftindia.com	Autoclave CH 8Alarm Alerts IAS	Autoclave CH 8 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
7	01-Mar-2023 18:11:50	Environmental Shaker CH 2	rohan@dreamsoftindia.com	Environmental Shaker CH 2Alarm Alerts IAS	Environmental Shaker CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
8	01-Mar-2023 18:11:50	Environmental Shaker CH 2	rohan@dreamsoftindia.com	Environmental Shaker CH 2Alarm Alerts IAS	Environmental Shaker CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise

Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
9	01-Mar-2023 18:11:50	Environmental Shaker CH 10	rohan@dreamsoftindia.com	Environmental Shaker CH 10Alarm Alerts IAS	Environmental Shaker CH 10 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
10	01-Mar-2023 18:11:50	Environmental Shaker CH 10	rohan@dreamsoftindia.com	Environmental Shaker CH 10Alarm Alerts IAS	Environmental Shaker CH 10 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
11	01-Mar-2023 18:11:50	Cold Room Humidity CH 2	rohan@dreamsoftindia.com	Cold Room Humidity CH 2Alarm Alerts IAS	Cold Room Humidity CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
12	01-Mar-2023 18:11:50	Cold Room Humidity CH 2	rohan@dreamsoftindia.com	Cold Room Humidity CH 2Alarm Alerts IAS	Cold Room Humidity CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
13	01-Mar-2023 18:11:50	Stability Chambers CH 5	rohan@dreamsoftindia.com	Stability Chambers CH 5Alarm Alerts IAS	Stability Chambers CH 5 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
14	01-Mar-2023 18:11:50	Stability Chambers CH 5	rohan@dreamsoftindia.com	Stability Chambers CH 5Alarm Alerts IAS	Stability Chambers CH 5 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
15	01-Mar-2023 18:11:50	BOD Incubators	rohan@dreamsoftindia.com	BOD IncubatorsAlarm Alerts IAS	BOD Incubators CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
16	01-Mar-2023 18:11:50	BOD Incubators	rohan@dreamsoftindia.com	BOD IncubatorsAlarm Alerts IAS	BOD Incubators CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
17	01-Mar-2023 18:11:50	Freezer CH 2	rohan@dreamsoftindia.com	Freezer CH 2Alarm Alerts IAS	Freezer CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
18	01-Mar-2023 18:11:50	Freezer CH 2	rohan@dreamsoftindia.com	Freezer CH 2Alarm Alerts IAS	Freezer CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
19	01-Mar-2023 18:11:50	Photo Stability Humidity	rohan@dreamsoftindia.com	Photo Stability HumidityAlarm Alerts IAS	Photo Stability Humidity CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
20	01-Mar-2023 18:11:50	Photo Stability Humidity	rohan@dreamsoftindia.com	Photo Stability HumidityAlarm Alerts IAS	Photo Stability Humidity CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
21	01-Mar-2023 18:11:50	Photo Stability CH 7	rohan@dreamsoftindia.com	Photo Stability CH 7Alarm Alerts IAS	Photo Stability CH 7 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
22	01-Mar-2023 18:11:50	Photo Stability CH 7	rohan@dreamsoftindia.com	Photo Stability CH 7Alarm Alerts IAS	Photo Stability CH 7 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
23	01-Mar-2023 18:11:50	Plant growth chamber humidiy	rohan@dreamsoftindia.com	Plant growth chamber humidiyAlarm Alerts IAS	Plant growth chamber humidiy CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
24	01-Mar-2023 18:11:50	Plant growth chamber humidiy	rohan@dreamsoftindia.com	Plant growth chamber humidiyAlarm Alerts IAS	Plant growth chamber humidiy CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise

Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
25	01-Mar-2023 18:11:50	Plant Growth Chamber CH 5	rohan@dreamsoftindia.com	Plant Growth Chamber CH 5Alarm Alerts IAS	Plant Growth Chamber CH 5 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
26	01-Mar-2023 18:11:50	Plant Growth Chamber CH 5	rohan@dreamsoftindia.com	Plant Growth Chamber CH 5Alarm Alerts IAS	Plant Growth Chamber CH 5 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
27	01-Mar-2023 18:11:50	Shaker Incubator CH 2	rohan@dreamsoftindia.com	Shaker Incubator CH 2Alarm Alerts IAS	Shaker Incubator CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
28	01-Mar-2023 18:11:50	Shaker Incubator CH 2	rohan@dreamsoftindia.com	Shaker Incubator CH 2Alarm Alerts IAS	Shaker Incubator CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
29	01-Mar-2023 18:11:50	Shaker Incubator CH 15	rohan@dreamsoftindia.com	Shaker Incubator CH 15Alarm Alerts IAS	Shaker Incubator CH 15 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
30	01-Mar-2023 18:11:50	Shaker Incubator CH 15	rohan@dreamsoftindia.com	Shaker Incubator CH 15Alarm Alerts IAS	Shaker Incubator CH 15 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
31	01-Mar-2023 18:11:50	Autoclave CH 10	rohan@dreamsoftindia.com	Autoclave CH 10Alarm Alerts IAS	Autoclave CH 10 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
32	01-Mar-2023 18:11:50	Autoclave CH 10	rohan@dreamsoftindia.com	Autoclave CH 10Alarm Alerts IAS	Autoclave CH 10 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise

Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
33	01-Mar-2023 18:11:50	BOD Incubator CH 12	rohan@dreamsoftindia.com	BOD Incubator CH 12Alarm Alerts IAS	BOD Incubator CH 12 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
34	01-Mar-2023 18:11:50	BOD Incubator CH 12	rohan@dreamsoftindia.com	BOD Incubator CH 12Alarm Alerts IAS	BOD Incubator CH 12 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
35	01-Mar-2023 18:11:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
36	01-Mar-2023 18:11:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:36PM		SENT
37	01-Mar-2023 18:11:50	BOD Incubator CH 12	rohan@dreamsoftindia.com	BOD Incubator CH 12Alarm Alerts IAS	BOD Incubator CH 12 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
38	01-Mar-2023 18:11:50	BOD Incubator CH 12	rohan@dreamsoftindia.com	BOD Incubator CH 12Alarm Alerts IAS	BOD Incubator CH 12 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
39	01-Mar-2023 18:11:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
40	01-Mar-2023 18:11:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise

Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
41	01-Mar-2023 18:11:50	Shaker Incubator CH 15	rohan@dreamsoftindia.com	Shaker Incubator CH 15Alarm Alerts IAS	Shaker Incubator CH 15 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
42	01-Mar-2023 18:11:50	Shaker Incubator CH 15	rohan@dreamsoftindia.com	Shaker Incubator CH 15Alarm Alerts IAS	Shaker Incubator CH 15 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
43	01-Mar-2023 18:11:50	Autoclave CH 10	rohan@dreamsoftindia.com	Autoclave CH 10Alarm Alerts IAS	Autoclave CH 10 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
44	01-Mar-2023 18:11:50	Autoclave CH 10	rohan@dreamsoftindia.com	Autoclave CH 10Alarm Alerts IAS	Autoclave CH 10 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
45	01-Mar-2023 18:11:50	Shaker Incubator CH 2	rohan@dreamsoftindia.com	Shaker Incubator CH 2Alarm Alerts IAS	Shaker Incubator CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
46	01-Mar-2023 18:11:50	Shaker Incubator CH 2	rohan@dreamsoftindia.com	Shaker Incubator CH 2Alarm Alerts IAS	Shaker Incubator CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
47	01-Mar-2023 18:11:50	Plant Growth Chamber CH 5	rohan@dreamsoftindia.com	Plant Growth Chamber CH 5Alarm Alerts IAS	Plant Growth Chamber CH 5 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
48	01-Mar-2023 18:11:50	Plant Growth Chamber CH 5	rohan@dreamsoftindia.com	Plant Growth Chamber CH 5Alarm Alerts IAS	Plant Growth Chamber CH 5 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise

Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
49	01-Mar-2023 18:11:50	Plant growth chamber humidiy	rohan@dreamsoftindia.com	Plant growth chamber chamber humidiyAlarm Alerts IAS	Plant growth chamber humidiy CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
50	01-Mar-2023 18:11:50	Plant growth chamber humidiy	rohan@dreamsoftindia.com	Plant growth chamber chamber humidiyAlarm Alerts IAS	Plant growth chamber humidiy CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
51	01-Mar-2023 18:11:50	BOD Incubators	rohan@dreamsoftindia.com	BOD IncubatorsAlarm Alerts IAS	BOD Incubators CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
52	01-Mar-2023 18:11:50	BOD Incubators	rohan@dreamsoftindia.com	BOD IncubatorsAlarm Alerts IAS	BOD Incubators CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
53	01-Mar-2023 18:11:50	Photo Stability CH 7	rohan@dreamsoftindia.com	Photo Stability CH 7Alarm Alerts IAS	Photo Stability CH 7 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
54	01-Mar-2023 18:11:50	Photo Stability CH 7	rohan@dreamsoftindia.com	Photo Stability CH 7Alarm Alerts IAS	Photo Stability CH 7 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
55	01-Mar-2023 18:11:50	Photo Stability Humidity	rohan@dreamsoftindia.com	Photo Stability HumidityAlarm Alerts IAS	Photo Stability Humidity CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
56	01-Mar-2023 18:11:50	Photo Stability Humidity	rohan@dreamsoftindia.com	Photo Stability HumidityAlarm Alerts IAS	Photo Stability Humidity CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
57	01-Mar-2023 18:11:50	Freezer CH 2	rohan@dreamsoftindia.com	Freezer CH 2Alarm Alerts IAS	Freezer CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
58	01-Mar-2023 18:11:50	Freezer CH 2	rohan@dreamsoftindia.com	Freezer CH 2Alarm Alerts IAS	Freezer CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
59	01-Mar-2023 18:11:50	Cold Room Humidity CH 2	rohan@dreamsoftindia.com	Cold Room Humidity CH 2Alarm Alerts IAS	Cold Room Humidity CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
60	01-Mar-2023 18:11:50	Cold Room Humidity CH 2	rohan@dreamsoftindia.com	Cold Room Humidity CH 2Alarm Alerts IAS	Cold Room Humidity CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
61	01-Mar-2023 18:11:50	Environmental Shaker CH 10	rohan@dreamsoftindia.com	Environmental Shaker CH 10Alarm Alerts IAS	Environmental Shaker CH 10 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
62	01-Mar-2023 18:11:50	Environmental Shaker CH 10	rohan@dreamsoftindia.com	Environmental Shaker CH 10Alarm Alerts IAS	Environmental Shaker CH 10 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
63	01-Mar-2023 18:11:50	Stability Chambers CH 5	rohan@dreamsoftindia.com	Stability Chambers CH 5Alarm Alerts IAS	Stability Chambers CH 5 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
64	01-Mar-2023 18:11:50	Stability Chambers CH 5	rohan@dreamsoftindia.com	Stability Chambers CH 5Alarm Alerts IAS	Stability Chambers CH 5 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise

Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
65	01-Mar-2023 18:11:50	Environmental Shaker CH 2	rohan@dreamsoftindia.com	Environmental Shaker CH 2Alarm Alerts IAS	Environmental Shaker CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
66	01-Mar-2023 18:11:50	Environmental Shaker CH 2	rohan@dreamsoftindia.com	Environmental Shaker CH 2Alarm Alerts IAS	Environmental Shaker CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
67	01-Mar-2023 18:11:50	Autoclave CH 8	rohan@dreamsoftindia.com	Autoclave CH 8Alarm Alerts IAS	Autoclave CH 8 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
68	01-Mar-2023 18:11:50	Autoclave CH 8	rohan@dreamsoftindia.com	Autoclave CH 8Alarm Alerts IAS	Autoclave CH 8 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
69	01-Mar-2023 18:11:50	Autoclave CH 2	rohan@dreamsoftindia.com	Autoclave CH 2Alarm Alerts IAS	Autoclave CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
70	01-Mar-2023 18:11:50	Autoclave CH 2	rohan@dreamsoftindia.com	Autoclave CH 2Alarm Alerts IAS	Autoclave CH 2 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
71	01-Mar-2023 18:11:50	Eq_1	rohan@dreamsoftindia.com	Eq_1Alarm Alerts IAS	Eq_1 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
72	01-Mar-2023 18:11:50	Eq_1	rohan@dreamsoftindia.com	Eq_1Alarm Alerts IAS	Eq_1 CHAMBER THERMOSTAT CUT OFF Jan 11 2023 7:39PM		SENT
73	01-Mar-2023 18:11:50	Eq_1	rohan@dreamsoftindia.com	Eq_1Alarm Alerts IAS	Eq_1 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT

FOOTER NOTE

Printed By - Administrator On 16-Mar-2023 18:38:02

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
74	01-Mar-2023 18:11:50	Eq_1	rohan@dreamsoftindia.com	Eq_1Alarm Alerts IAS	Eq_1 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
75	01-Mar-2023 18:11:50	Autoclave CH 2	rohan@dreamsoftindia.com	Autoclave CH 2Alarm Alerts IAS	Autoclave CH 2 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
76	01-Mar-2023 18:11:50	Autoclave CH 2	rohan@dreamsoftindia.com	Autoclave CH 2Alarm Alerts IAS	Autoclave CH 2 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
77	01-Mar-2023 18:11:50	Autoclave CH 8	rohan@dreamsoftindia.com	Autoclave CH 8Alarm Alerts IAS	Autoclave CH 8 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
78	01-Mar-2023 18:11:50	Autoclave CH 8	rohan@dreamsoftindia.com	Autoclave CH 8Alarm Alerts IAS	Autoclave CH 8 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
79	01-Mar-2023 18:11:50	Stability Chambers CH 5	rohan@dreamsoftindia.com	Stability Chambers CH 5Alarm Alerts IAS	Stability Chambers CH 5 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
80	01-Mar-2023 18:11:50	Stability Chambers CH 5	rohan@dreamsoftindia.com	Stability Chambers CH 5Alarm Alerts IAS	Stability Chambers CH 5 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
81	01-Mar-2023 18:11:50	Cold Room Humidity CH 2	rohan@dreamsoftindia.com	Cold Room Humidity CH 2Alarm Alerts IAS	Cold Room Humidity CH 2 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
82	01-Mar-2023 18:11:50	Cold Room Humidity CH 2	rohan@dreamsoftindia.com	Cold Room Humidity CH 2Alarm Alerts IAS	Cold Room Humidity CH 2 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
83	01-Mar-2023 18:11:50	Photo Stability Humidity	rohan@dreamsoftindia.com	Photo Stability HumidityAlarm Alerts IAS	Photo Stability Humidity TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
84	01-Mar-2023 18:11:50	Photo Stability Humidity	rohan@dreamsoftindia.com	Photo Stability HumidityAlarm Alerts IAS	Photo Stability Humidity TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT

FOOTER NOTE

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
85	01-Mar-2023 18:11:50	Photo Stability CH 7	rohan@dreamsoftindia.com	Photo Stability CH 7Alarm Alerts IAS	Photo Stability CH 7 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
86	01-Mar-2023 18:11:50	Photo Stability CH 7	rohan@dreamsoftindia.com	Photo Stability CH 7Alarm Alerts IAS	Photo Stability CH 7 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
87	01-Mar-2023 18:11:50	Plant growth chamber humidiy	rohan@dreamsoftindia.com	Plant growth chamber humidiyAlarm Alerts IAS	Plant growth chamber humidiy TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
88	01-Mar-2023 18:11:50	Plant growth chamber humidiy	rohan@dreamsoftindia.com	Plant growth chamber humidiyAlarm Alerts IAS	Plant growth chamber humidiy TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
89	01-Mar-2023 18:11:50	Plant Growth Chamber CH 5	rohan@dreamsoftindia.com	Plant Growth Chamber CH 5Alarm Alerts IAS	Plant Growth Chamber CH 5 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
90	01-Mar-2023 18:11:50	Plant Growth Chamber CH 5	rohan@dreamsoftindia.com	Plant Growth Chamber CH 5Alarm Alerts IAS	Plant Growth Chamber CH 5 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
91	01-Mar-2023 18:11:50	Shaker Incubator CH 2	rohan@dreamsoftindia.com	Shaker Incubator CH 2Alarm Alerts IAS	Shaker Incubator CH 2 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
92	01-Mar-2023 18:11:50	Shaker Incubator CH 2	rohan@dreamsoftindia.com	Shaker Incubator CH 2Alarm Alerts IAS	Shaker Incubator CH 2 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
93	01-Mar-2023 18:11:50	Shaker Incubator CH 15	rohan@dreamsoftindia.com	Shaker Incubator CH 15Alarm Alerts IAS	Shaker Incubator CH 15 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
94	01-Mar-2023 18:11:50	Shaker Incubator CH 15	rohan@dreamsoftindia.com	Shaker Incubator CH 15Alarm Alerts IAS	Shaker Incubator CH 15 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT

Client Logo	COMPANY NAME PLANT NAME QA Department	
--------------------	---	--

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
95	01-Mar-2023 18:11:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
96	01-Mar-2023 18:11:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM		SENT
97	01-Mar-2023 18:11:50	Autoclave CH 10	rohan@dreamsoftindia.com	Autoclave CH 10Alarm Alerts IAS	Autoclave CH 10 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
98	01-Mar-2023 18:11:50	Autoclave CH 10	rohan@dreamsoftindia.com	Autoclave CH 10Alarm Alerts IAS	Autoclave CH 10 TEMPERATURE HIGH ALARM Jan 16 2023 8:07PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
99	01-Mar-2023 18:11:50	Autoclave CH 10	rohan@dreamsoftindia.com	Autoclave CH 10Alarm Alerts IAS	Autoclave CH 10 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME PLANT NAME QA Department	
--------------------	---	--

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
100	01-Mar-2023 18:11:50	Autoclave CH 10	rohan@dreamsoftindia.com	Autoclave CH 10Alarm Alerts IAS	Autoclave CH 10 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
101	01-Mar-2023 18:11:50	Plant growth chamber humidiy	rohan@dreamsoftindia.com	Plant growth chamber humidiyAlarm Alerts IAS	Plant growth chamber humidiy TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
102	01-Mar-2023 18:11:50	Plant growth chamber humidiy	rohan@dreamsoftindia.com	Plant growth chamber humidiyAlarm Alerts IAS	Plant growth chamber humidiy TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
103	01-Mar-2023 18:11:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME PLANT NAME QA Department
--------------------	---

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
104	01-Mar-2023 18:11:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
105	01-Mar-2023 18:11:50	Shaker Incubator CH 15	rohan@dreamsoftindia.com	Shaker Incubator CH 15Alarm Alerts IAS	Shaker Incubator CH 15 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
106	01-Mar-2023 18:11:50	Shaker Incubator CH 15	rohan@dreamsoftindia.com	Shaker Incubator CH 15Alarm Alerts IAS	Shaker Incubator CH 15 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
107	01-Mar-2023 18:11:50	Plant Growth Chamber CH 5	rohan@dreamsoftindia.com	Plant Growth Chamber CH 5Alarm Alerts IAS	Plant Growth Chamber CH 5 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME PLANT NAME QA Department	
--------------------	--	--

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
108	01-Mar-2023 18:11:50	Plant Growth Chamber CH 5	rohan@dreamsoftindia.com	Plant Growth Chamber CH 5Alarm Alerts IAS	Plant Growth Chamber CH 5 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
109	01-Mar-2023 18:11:50	Shaker Incubator CH 2	rohan@dreamsoftindia.com	Shaker Incubator CH 2Alarm Alerts IAS	Shaker Incubator CH 2 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
110	01-Mar-2023 18:11:50	Shaker Incubator CH 2	rohan@dreamsoftindia.com	Shaker Incubator CH 2Alarm Alerts IAS	Shaker Incubator CH 2 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
111	01-Mar-2023 18:11:50	Photo Stability CH 7	rohan@dreamsoftindia.com	Photo Stability CH 7Alarm Alerts IAS	Photo Stability CH 7 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME PLANT NAME QA Department
--------------------	---

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
112	01-Mar-2023 18:11:50	Photo Stability CH 7	rohan@dreamsoftindia.com	Photo Stability CH 7Alarm Alerts IAS	Photo Stability CH 7 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
113	01-Mar-2023 18:11:50	Photo Stability Humidity	rohan@dreamsoftindia.com	Photo Stability HumidityAlarm Alerts IAS	Photo Stability Humidity TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
114	01-Mar-2023 18:11:50	Photo Stability Humidity	rohan@dreamsoftindia.com	Photo Stability HumidityAlarm Alerts IAS	Photo Stability Humidity TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
115	01-Mar-2023 18:11:50	Stability Chambers CH 5	rohan@dreamsoftindia.com	Stability Chambers CH 5Alarm Alerts IAS	Stability Chambers CH 5 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME PLANT NAME QA Department	
--------------------	---	--

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
116	01-Mar-2023 18:11:50	Stability Chambers CH 5	rohan@dreamsoftindia.com	Stability Chambers CH 5Alarm Alerts IAS	Stability Chambers CH 5 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
117	01-Mar-2023 18:11:50	Cold Room Humidity CH 2	rohan@dreamsoftindia.com	Cold Room Humidity CH 2Alarm Alerts IAS	Cold Room Humidity CH 2 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
118	01-Mar-2023 18:11:50	Cold Room Humidity CH 2	rohan@dreamsoftindia.com	Cold Room Humidity CH 2Alarm Alerts IAS	Cold Room Humidity CH 2 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
119	01-Mar-2023 18:11:50	Autoclave CH 8	rohan@dreamsoftindia.com	Autoclave CH 8Alarm Alerts IAS	Autoclave CH 8 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME PLANT NAME QA Department	
--------------------	---	--

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
120	01-Mar-2023 18:11:50	Autoclave CH 8	rohan@dreamsoftindia.com	Autoclave CH 8Alarm Alerts IAS	Autoclave CH 8 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
121	01-Mar-2023 18:11:50	Autoclave CH 2	rohan@dreamsoftindia.com	Autoclave CH 2Alarm Alerts IAS	Autoclave CH 2 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
122	01-Mar-2023 18:11:50	Autoclave CH 2	rohan@dreamsoftindia.com	Autoclave CH 2Alarm Alerts IAS	Autoclave CH 2 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
123	01-Mar-2023 18:11:50	Eq_1	rohan@dreamsoftindia.com	Eq_1Alarm Alerts IAS	Eq_1 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME PLANT NAME QA Department
--------------------	--

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
124	01-Mar-2023 18:11:50	Eq_1	rohan@dreamsoftindia.com	Eq_1Alarm Alerts IAS	Eq_1 TEMPERATURE HIGH ALARM Jan 18 2023 4:13PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
125	01-Mar-2023 18:11:50	Eq_1	rohan@dreamsoftindia.com	Eq_1Alarm Alerts IAS	Eq_1 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
126	01-Mar-2023 18:11:50	Eq_1	rohan@dreamsoftindia.com	Eq_1Alarm Alerts IAS	Eq_1 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
127	01-Mar-2023 18:11:50	Autoclave CH 2	rohan@dreamsoftindia.com	Autoclave CH 2Alarm Alerts IAS	Autoclave CH 2 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
128	01-Mar-2023 18:11:50	Autoclave CH 2	rohan@dreamsoftindia.com	Autoclave CH 2Alarm Alerts IAS	Autoclave CH 2 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
129	01-Mar-2023 18:11:50	Autoclave CH 8	rohan@dreamsoftindia.com	Autoclave CH 8Alarm Alerts IAS	Autoclave CH 8 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
130	01-Mar-2023 18:11:50	Autoclave CH 8	rohan@dreamsoftindia.com	Autoclave CH 8Alarm Alerts IAS	Autoclave CH 8 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
131	01-Mar-2023 18:11:50	Environmental Shaker CH 2	rohan@dreamsoftindia.com	Environmental Shaker CH 2Alarm Alerts IAS	Environmental Shaker CH 2 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
132	01-Mar-2023 18:11:50	Environmental Shaker CH 2	rohan@dreamsoftindia.com	Environmental Shaker CH 2Alarm Alerts IAS	Environmental Shaker CH 2 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
133	01-Mar-2023 18:11:50	Environmental Shaker CH 10	rohan@dreamsoftindia.com	Environmental Shaker CH 10Alarm Alerts IAS	Environmental Shaker CH 10 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
134	01-Mar-2023 18:11:50	Environmental Shaker CH 10	rohan@dreamsoftindia.com	Environmental Shaker CH 10Alarm Alerts IAS	Environmental Shaker CH 10 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
135	01-Mar-2023 18:11:50	Stability Chambers CH 5	rohan@dreamsoftindia.com	Stability Chambers CH 5Alarm Alerts IAS	Stability Chambers CH 5 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
136	01-Mar-2023 18:11:50	Stability Chambers CH 5	rohan@dreamsoftindia.com	Stability Chambers CH 5Alarm Alerts IAS	Stability Chambers CH 5 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
137	01-Mar-2023 18:11:50	Cold Room Humidity CH 2	rohan@dreamsoftindia.com	Cold Room Humidity CH 2Alarm Alerts IAS	Cold Room Humidity CH 2 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
138	01-Mar-2023 18:11:50	Cold Room Humidity CH 2	rohan@dreamsoftindia.com	Cold Room Humidity CH 2Alarm Alerts IAS	Cold Room Humidity CH 2 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
139	01-Mar-2023 18:11:50	Photo Stability Humidity	rohan@dreamsoftindia.com	Photo Stability HumidityAlarm Alerts IAS	Photo Stability Humidity TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME PLANT NAME QA Department
--------------------	---

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
140	01-Mar-2023 18:11:50	Photo Stability Humidity	rohan@dreamsoftindia.com	Photo Stability HumidityAlarm Alerts IAS	Photo Stability Humidity TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
141	01-Mar-2023 18:11:50	BOD Incubators	rohan@dreamsoftindia.com	BOD IncubatorsAlarm Alerts IAS	BOD Incubators TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
142	01-Mar-2023 18:11:50	BOD Incubators	rohan@dreamsoftindia.com	BOD IncubatorsAlarm Alerts IAS	BOD Incubators TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
143	01-Mar-2023 18:11:50	Freezer CH 2	rohan@dreamsoftindia.com	Freezer CH 2Alarm Alerts IAS	Freezer CH 2 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME PLANT NAME QA Department
--------------------	---

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
144	01-Mar-2023 18:11:50	Freezer CH 2	rohan@dreamsoftindia.com	Freezer CH 2Alarm Alerts IAS	Freezer CH 2 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
145	01-Mar-2023 18:11:50	Photo Stability CH 7	rohan@dreamsoftindia.com	Photo Stability CH 7Alarm Alerts IAS	Photo Stability CH 7 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
146	01-Mar-2023 18:11:50	Photo Stability CH 7	rohan@dreamsoftindia.com	Photo Stability CH 7Alarm Alerts IAS	Photo Stability CH 7 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
147	01-Mar-2023 18:11:50	Plant Growth Chamber CH 5	rohan@dreamsoftindia.com	Plant Growth Chamber CH 5Alarm Alerts IAS	Plant Growth Chamber CH 5 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
148	01-Mar-2023 18:11:50	Plant Growth Chamber CH 5	rohan@dreamsoftindia.com	Plant Growth Chamber CH 5Alarm Alerts IAS	Plant Growth Chamber CH 5 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
149	01-Mar-2023 18:11:50	Plant growth chamber humidiy	rohan@dreamsoftindia.com	Plant growth chamber humidiyAlarm Alerts IAS	Plant growth chamber humidiy TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
150	01-Mar-2023 18:11:50	Plant growth chamber humidiy	rohan@dreamsoftindia.com	Plant growth chamber humidiyAlarm Alerts IAS	Plant growth chamber humidiy TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
151	01-Mar-2023 18:11:50	Autoclave CH 10	rohan@dreamsoftindia.com	Autoclave CH 10Alarm Alerts IAS	Autoclave CH 10 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
152	01-Mar-2023 18:11:50	Autoclave CH 10	rohan@dreamsoftindia.com	Autoclave CH 10Alarm Alerts IAS	Autoclave CH 10 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
153	01-Mar-2023 18:11:50	Shaker Incubator CH 15	rohan@dreamsoftindia.com	Shaker Incubator CH 15Alarm Alerts IAS	Shaker Incubator CH 15 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
154	01-Mar-2023 18:11:50	Shaker Incubator CH 15	rohan@dreamsoftindia.com	Shaker Incubator CH 15Alarm Alerts IAS	Shaker Incubator CH 15 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
155	01-Mar-2023 18:11:50	Shaker Incubator CH 2	rohan@dreamsoftindia.com	Shaker Incubator CH 2Alarm Alerts IAS	Shaker Incubator CH 2 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME PLANT NAME QA Department
--------------------	---

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
156	01-Mar-2023 18:11:50	Shaker Incubator CH 2	rohan@dreamsoftindia.com	Shaker Incubator CH 2Alarm Alerts IAS	Shaker Incubator CH 2 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
157	01-Mar-2023 18:11:50	BOD Incubator CH 12	rohan@dreamsoftindia.com	BOD Incubator CH 12Alarm Alerts IAS	BOD Incubator CH 12 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
158	01-Mar-2023 18:11:50	BOD Incubator CH 12	rohan@dreamsoftindia.com	BOD Incubator CH 12Alarm Alerts IAS	BOD Incubator CH 12 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
159	01-Mar-2023 18:11:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME PLANT NAME QA Department	
--------------------	---	--

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
160	01-Mar-2023 18:11:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 TEMP. IN RANGE FROM HIGH Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
161	01-Mar-2023 18:11:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
162	01-Mar-2023 18:11:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
163	01-Mar-2023 18:11:50	Autoclave CH 10	rohan@dreamsoftindia.com	Autoclave CH 10Alarm Alerts IAS	Autoclave CH 10 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME PLANT NAME QA Department	
--------------------	---	--

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
164	01-Mar-2023 18:11:50	Autoclave CH 10	rohan@dreamsoftindia.com	Autoclave CH 10Alarm Alerts IAS	Autoclave CH 10 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
165	01-Mar-2023 18:11:50	Shaker Incubator CH 15	rohan@dreamsoftindia.com	Shaker Incubator CH 15Alarm Alerts IAS	Shaker Incubator CH 15 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
166	01-Mar-2023 18:11:50	Shaker Incubator CH 15	rohan@dreamsoftindia.com	Shaker Incubator CH 15Alarm Alerts IAS	Shaker Incubator CH 15 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
167	01-Mar-2023 18:11:50	Shaker Incubator CH 2	rohan@dreamsoftindia.com	Shaker Incubator CH 2Alarm Alerts IAS	Shaker Incubator CH 2 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME PLANT NAME QA Department
--------------------	---

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
168	01-Mar-2023 18:11:50	Shaker Incubator CH 2	rohan@dreamsoftindia.com	Shaker Incubator CH 2Alarm Alerts IAS	Shaker Incubator CH 2 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
169	01-Mar-2023 18:11:50	Plant growth chamber humidiy	rohan@dreamsoftindia.com	Plant growth chamber humidiyAlarm Alerts IAS	Plant growth chamber humidiy TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
170	01-Mar-2023 18:11:50	Plant growth chamber humidiy	rohan@dreamsoftindia.com	Plant growth chamber humidiyAlarm Alerts IAS	Plant growth chamber humidiy TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
171	01-Mar-2023 18:11:50	Plant Growth Chamber CH 5	rohan@dreamsoftindia.com	Plant Growth Chamber CH 5Alarm Alerts IAS	Plant Growth Chamber CH 5 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
172	01-Mar-2023 18:11:50	Plant Growth Chamber CH 5	rohan@dreamsoftindia.com	Plant Growth Chamber CH 5Alarm Alerts IAS	Plant Growth Chamber CH 5 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
173	01-Mar-2023 18:11:50	Photo Stability CH 7	rohan@dreamsoftindia.com	Photo Stability CH 7Alarm Alerts IAS	Photo Stability CH 7 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
174	01-Mar-2023 18:11:50	Photo Stability CH 7	rohan@dreamsoftindia.com	Photo Stability CH 7Alarm Alerts IAS	Photo Stability CH 7 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
175	01-Mar-2023 18:11:50	Photo Stability Humidity	rohan@dreamsoftindia.com	Photo Stability HumidityAlarm Alerts IAS	Photo Stability Humidity TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME PLANT NAME QA Department
--------------------	---

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
176	01-Mar-2023 18:11:50	Photo Stability Humidity	rohan@dreamsoftindia.com	Photo Stability HumidityAlarm Alerts IAS	Photo Stability Humidity TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
177	01-Mar-2023 18:11:50	Stability Chambers CH 5	rohan@dreamsoftindia.com	Stability Chambers CH 5Alarm Alerts IAS	Stability Chambers CH 5 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
178	01-Mar-2023 18:11:50	Stability Chambers CH 5	rohan@dreamsoftindia.com	Stability Chambers CH 5Alarm Alerts IAS	Stability Chambers CH 5 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
179	01-Mar-2023 18:11:50	Cold Room Humidity CH 2	rohan@dreamsoftindia.com	Cold Room Humidity CH 2Alarm Alerts IAS	Cold Room Humidity CH 2 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME PLANT NAME QA Department	
--------------------	---	--

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
180	01-Mar-2023 18:11:50	Cold Room Humidity CH 2	rohan@dreamsoftindia.com	Cold Room Humidity CH 2Alarm Alerts IAS	Cold Room Humidity CH 2 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
181	01-Mar-2023 18:11:50	Autoclave CH 8	rohan@dreamsoftindia.com	Autoclave CH 8Alarm Alerts IAS	Autoclave CH 8 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
182	01-Mar-2023 18:11:50	Autoclave CH 8	rohan@dreamsoftindia.com	Autoclave CH 8Alarm Alerts IAS	Autoclave CH 8 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
183	01-Mar-2023 18:11:50	Autoclave CH 2	rohan@dreamsoftindia.com	Autoclave CH 2Alarm Alerts IAS	Autoclave CH 2 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME PLANT NAME QA Department	
--------------------	---	--

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
184	01-Mar-2023 18:11:50	Autoclave CH 2	rohan@dreamsoftindia.com	Autoclave CH 2Alarm Alerts IAS	Autoclave CH 2 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
185	01-Mar-2023 18:11:50	Eq_1	rohan@dreamsoftindia.com	Eq_1Alarm Alerts IAS	Eq_1 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
186	01-Mar-2023 18:11:50	Eq_1	rohan@dreamsoftindia.com	Eq_1Alarm Alerts IAS	Eq_1 TEMPERATURE LOW ALARM Jan 18 2023 6:05PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
187	01-Mar-2023 18:11:50	Eq_1	rohan@dreamsoftindia.com	Eq_1Alarm Alerts IAS	Eq_1 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME PLANT NAME QA Department
--------------------	---

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
188	01-Mar-2023 18:11:50	Eq_1	rohan@dreamsoftindia.com	Eq_1Alarm Alerts IAS	Eq_1 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
189	01-Mar-2023 18:11:50	Autoclave CH 2	rohan@dreamsoftindia.com	Autoclave CH 2Alarm Alerts IAS	Autoclave CH 2 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
190	01-Mar-2023 18:11:50	Autoclave CH 2	rohan@dreamsoftindia.com	Autoclave CH 2Alarm Alerts IAS	Autoclave CH 2 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
191	01-Mar-2023 18:11:50	Autoclave CH 8	rohan@dreamsoftindia.com	Autoclave CH 8Alarm Alerts IAS	Autoclave CH 8 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME PLANT NAME QA Department
--------------------	---

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
192	01-Mar-2023 18:11:50	Autoclave CH 8	rohan@dreamsoftindia.com	Autoclave CH 8Alarm Alerts IAS	Autoclave CH 8 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
193	01-Mar-2023 18:11:50	Environmental Shaker CH 2	rohan@dreamsoftindia.com	Environmental Shaker CH 2Alarm Alerts IAS	Environmental Shaker CH 2 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
194	01-Mar-2023 18:11:50	Environmental Shaker CH 2	rohan@dreamsoftindia.com	Environmental Shaker CH 2Alarm Alerts IAS	Environmental Shaker CH 2 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
195	01-Mar-2023 18:11:50	Environmental Shaker CH 10	rohan@dreamsoftindia.com	Environmental Shaker CH 10Alarm Alerts IAS	Environmental Shaker CH 10 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
196	01-Mar-2023 18:11:50	Environmental Shaker CH 10	rohan@dreamsoftindia.com	Environmental Shaker CH 10Alarm Alerts IAS	Environmental Shaker CH 10 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM	Error in processing. The server response was: Requested action aborted: This mail account has sent too many messages in a short amount of time. Please try later.	FAILED
197	01-Mar-2023 18:11:50	Cold Room Humidity CH 2	rohan@dreamsoftindia.com	Cold Room Humidity CH 2Alarm Alerts IAS	Cold Room Humidity CH 2 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
198	01-Mar-2023 18:11:50	Cold Room Humidity CH 2	rohan@dreamsoftindia.com	Cold Room Humidity CH 2Alarm Alerts IAS	Cold Room Humidity CH 2 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
199	01-Mar-2023 18:11:50	Photo Stability Humidity	rohan@dreamsoftindia.com	Photo Stability HumidityAlarm Alerts IAS	Photo Stability Humidity TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
200	01-Mar-2023 18:11:50	Photo Stability Humidity	rohan@dreamsoftindia.com	Photo Stability HumidityAlarm Alerts IAS	Photo Stability Humidity TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
201	01-Mar-2023 18:11:50	Freezer CH 2	rohan@dreamsoftindia.com	Freezer CH 2Alarm Alerts IAS	Freezer CH 2 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
202	01-Mar-2023 18:11:50	Freezer CH 2	rohan@dreamsoftindia.com	Freezer CH 2Alarm Alerts IAS	Freezer CH 2 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
203	01-Mar-2023 18:11:50	BOD Incubators	rohan@dreamsoftindia.com	BOD IncubatorsAlarm Alerts IAS	BOD Incubators TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
204	01-Mar-2023 18:11:50	BOD Incubators	rohan@dreamsoftindia.com	BOD IncubatorsAlarm Alerts IAS	BOD Incubators TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
205	01-Mar-2023 18:11:50	Stability Chambers CH 5	rohan@dreamsoftindia.com	Stability Chambers CH 5Alarm Alerts IAS	Stability Chambers CH 5 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
206	01-Mar-2023 18:11:50	Stability Chambers CH 5	rohan@dreamsoftindia.com	Stability Chambers CH 5Alarm Alerts IAS	Stability Chambers CH 5 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
207	01-Mar-2023 18:11:50	Plant growth chamber humidiy	rohan@dreamsoftindia.com	Plant growth chamber humidiyAlarm Alerts IAS	Plant growth chamber humidiy TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
208	01-Mar-2023 18:11:50	Plant growth chamber humidiy	rohan@dreamsoftindia.com	Plant growth chamber humidiyAlarm Alerts IAS	Plant growth chamber humidiy TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
209	01-Mar-2023 18:11:50	Photo Stability CH 7	rohan@dreamsoftindia.com	Photo Stability CH 7Alarm Alerts IAS	Photo Stability CH 7 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
210	01-Mar-2023 18:11:50	Photo Stability CH 7	rohan@dreamsoftindia.com	Photo Stability CH 7Alarm Alerts IAS	Photo Stability CH 7 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
211	01-Mar-2023 18:11:50	Plant Growth Chamber CH 5	rohan@dreamsoftindia.com	Plant Growth Chamber CH 5Alarm Alerts IAS	Plant Growth Chamber CH 5 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
212	01-Mar-2023 18:11:50	Plant Growth Chamber CH 5	rohan@dreamsoftindia.com	Plant Growth Chamber CH 5Alarm Alerts IAS	Plant Growth Chamber CH 5 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
213	01-Mar-2023 18:11:50	Shaker Incubator CH 2	rohan@dreamsoftindia.com	Shaker Incubator CH 2Alarm Alerts IAS	Shaker Incubator CH 2 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
214	01-Mar-2023 18:11:50	Shaker Incubator CH 2	rohan@dreamsoftindia.com	Shaker Incubator CH 2Alarm Alerts IAS	Shaker Incubator CH 2 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise

Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
215	01-Mar-2023 18:11:50	Shaker Incubator CH 15	rohan@dreamsoftindia.com	Shaker Incubator CH 15Alarm Alerts IAS	Shaker Incubator CH 15 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
216	01-Mar-2023 18:11:50	Shaker Incubator CH 15	rohan@dreamsoftindia.com	Shaker Incubator CH 15Alarm Alerts IAS	Shaker Incubator CH 15 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
217	01-Mar-2023 18:11:50	Autoclave CH 10	rohan@dreamsoftindia.com	Autoclave CH 10Alarm Alerts IAS	Autoclave CH 10 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
218	01-Mar-2023 18:11:50	Autoclave CH 10	rohan@dreamsoftindia.com	Autoclave CH 10Alarm Alerts IAS	Autoclave CH 10 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
219	01-Mar-2023 18:11:50	BOD Incubator CH 12	rohan@dreamsoftindia.com	BOD Incubator CH 12Alarm Alerts IAS	BOD Incubator CH 12 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
220	01-Mar-2023 18:11:50	BOD Incubator CH 12	rohan@dreamsoftindia.com	BOD Incubator CH 12Alarm Alerts IAS	BOD Incubator CH 12 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
221	01-Mar-2023 18:11:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
222	01-Mar-2023 18:11:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 TEMP. IN RANGE FROM LOW Jan 18 2023 6:06PM		SENT
223	01-Mar-2023 18:11:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 TEMPERATURE LOW ALARM Mar 1 2023 4:02PM		SENT
224	01-Mar-2023 18:11:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 TEMPERATURE LOW ALARM Mar 1 2023 4:02PM		SENT
225	01-Mar-2023 18:15:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 TEMP. IN RANGE FROM LOW Mar 1 2023 6:09PM		SENT

FOOTER NOTE

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise

Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
226	01-Mar-2023 18:15:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 TEMP. IN RANGE FROM LOW Mar 1 2023 6:09PM		SENT
227	01-Mar-2023 18:15:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 HUMIDITY HIGH ALARM Mar 1 2023 6:09PM		SENT
228	01-Mar-2023 18:15:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 HUMIDITY HIGH ALARM Mar 1 2023 6:09PM		SENT
229	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 COMPRESSOR 1 FAILURE Mar 1 2023 6:11PM		SENT
230	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 COMPRESSOR 1 FAILURE Mar 1 2023 6:11PM		SENT
231	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 STANDBY TEMPERATURE SENSOR FAULTY Mar 1 2023 6:11PM		SENT
232	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 STANDBY TEMPERATURE SENSOR FAULTY Mar 1 2023 6:11PM		SENT
233	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 STANDBY TEMPERATURE SENSOR FAULTY Mar 1 2023 6:12PM		SENT
234	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 STANDBY TEMPERATURE SENSOR FAULTY Mar 1 2023 6:12PM		SENT

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
235	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 MASTER TEMPERATURE SENSOR FAULTY Mar 1 2023 6:12PM		SENT
236	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 MASTER TEMPERATURE SENSOR FAULTY Mar 1 2023 6:12PM		SENT
237	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 STANDBY TEMPERATURE SENSOR FAULTY Mar 1 2023 6:12PM		SENT
238	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 STANDBY TEMPERATURE SENSOR FAULTY Mar 1 2023 6:12PM		SENT
239	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 MASTER TEMPERATURE SENSOR FAULTY Mar 1 2023 6:12PM		SENT
240	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 MASTER TEMPERATURE SENSOR FAULTY Mar 1 2023 6:12PM		SENT
241	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 STANDBY TEMPERATURE SENSOR FAULTY Mar 1 2023 6:12PM		SENT
242	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 STANDBY TEMPERATURE SENSOR FAULTY Mar 1 2023 6:12PM		SENT

Client Logo	COMPANY NAME		
	PLANT NAME		
	QA Department		

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
243	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 STANDBY TEMPERATURE SENSOR FAULTY Mar 1 2023 6:12PM		SENT
244	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 STANDBY TEMPERATURE SENSOR FAULTY Mar 1 2023 6:12PM		SENT
245	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 MASTER TEMPERATURE SENSOR FAULTY Mar 1 2023 6:12PM		SENT
246	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 MASTER TEMPERATURE SENSOR FAULTY Mar 1 2023 6:12PM		SENT
247	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 COMPRESSOR 2 FAILURE Mar 1 2023 6:12PM		SENT
248	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 COMPRESSOR 2 FAILURE Mar 1 2023 6:12PM		SENT
249	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 BOTH COMPRESSOR FAILURE Mar 1 2023 6:12PM		SENT
250	01-Mar-2023 18:17:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 BOTH COMPRESSOR FAILURE Mar 1 2023 6:12PM		SENT
251	01-Mar-2023 18:18:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 SG HEATER 1 FAILURE Mar 1 2023 6:12PM		SENT
252	01-Mar-2023 18:18:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 SG HEATER 1 FAILURE Mar 1 2023 6:12PM		SENT

FOOTER NOTE

Printed By - Administrator On 16-Mar-2023 18:38:02

Page 42 of 43

Client Logo	COMPANY NAME		
	PLANT NAME QA Department		

Email Audit Trail Date Wise			
Department	DEPARTMENT NAME		
Filter From	01-Mar-2023 00:00:00	Filter To	01-Mar-2023 18:35:53
Records From	01-Mar-2023 18:11:50	Records To	01-Mar-2023 18:18:50

Sr. No.	Log Date Time	Equipment / System	Email To	Email Subject	Email Message	Error Desc	Status
253	01-Mar-2023 18:18:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 SG HEATER 2 FAILURE Mar 1 2023 6:12PM		SENT
254	01-Mar-2023 18:18:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 SG HEATER 2 FAILURE Mar 1 2023 6:12PM		SENT
255	01-Mar-2023 18:18:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 BOTH SG HEATER FAILURE Mar 1 2023 6:12PM		SENT
256	01-Mar-2023 18:18:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 BOTH SG HEATER FAILURE Mar 1 2023 6:12PM		SENT
257	01-Mar-2023 18:18:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 MASTER RH SENSOR FAULTY Mar 1 2023 6:12PM		SENT
258	01-Mar-2023 18:18:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 MASTER RH SENSOR FAULTY Mar 1 2023 6:12PM		SENT
259	01-Mar-2023 18:18:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 STANDBY RH SENSOR FAULTY Mar 1 2023 6:12PM		SENT
260	01-Mar-2023 18:18:50	Cold Room Humidity CH11	rohan@dreamsoftindia.com	Cold Room Humidity CH11Alarm Alerts IAS	Cold Room Humidity CH11 STANDBY RH SENSOR FAULTY Mar 1 2023 6:12PM		SENT